

## Exit and Emergency Light Testing

The Australian Standard AS2293, specifically part 2 outlines a businesses requirement for the ongoing testing and maintenance of its exit and emergency lighting. Testing needs to be carried out every 6 months and includes

- Inspection of luminaries under normal operating conditions
- Full 90 minute discharge test to check battery performance
- Inspection of all lamps under test conditions
- Cleaning and inspection of diffusers
- Recording of all test results and any repairs required to remain compliant

If any batteries, lamps or fittings are deemed faulty, they must be replaced.

Failure to meet this standards requirements may result in hefty penalties, and more importantly, could put staff and visitors on site in danger in the case of an emergency or power outage.